

CODE: MBK17-060FC-VR

ERP: 0135605

## Fire Extinguisher 6Lt Wet Chemichal (BSI KITEMARK) BSI KITEMARK SERIES

6Lt Fire Extinguisher with Single Container Container with INTERIOR PLASTIC COATING.

**METAL BASE INCLUDED**

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



### CHARACTERISTICS

|                        |                 |
|------------------------|-----------------|
| Approval Type          | BSI             |
| Extinguisher Type      | Portable        |
| Pressure Type          | Stored Pressure |
| Suppression Agent Type | Wet Chemical    |
| Capacity               | 6Lt             |
| Extinguishing Agent    | 13A 75F         |
| Operating Temperature  | +5~+60 °C       |
| Max Allowable Pressure | 17 bar          |
| Text Pressure          | 30              |
| Volume of Equipment    | 7.8 L           |
| Cylinder Height        | 469±2 mm        |
| Cylinder Diameter      | 162±2 mm        |
| Cylinder Neck Thread   | M30x1.5         |
| Cylinder Material      | DC01            |
| Valve Material         | CuZn40Pb2       |
| Safety Valve           | 22-27 bar       |
| Approx. gross Weight   | 11.3 kg         |
| Approx. Dimensions     | 175x175x570 mm  |
| Paint Finish           | RAL 3000        |
| Packaging Details      | 1 τμχ.          |



Issue Date: 24/09/2024

Information may change

**HEADQUARTERS:** KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

**ATHENS DISTRIBUTION CENTER:** SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

**NORTH GREECE DISTRIBUTION CENTER:** 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

**CENTRAL & EAST CRETE DISTRIBUTION CENTER:** P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

**www.mobiakfire.com**